

**IEC****IECEE**

®

™

Ref. Certif. No.

**FR\_722768****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

**Lithium-Ion Battery**  
Rechargeable Li-ion Battery

Name and address of the applicant

**Zhejiang Hyxi Technology Co., Ltd.**  
Room 216, Block A, Building 1, No. 57 Jiang'er Road, Changhe Street, Binjiang District, Hangzhou, Zhejiang Province - China

Name and address of the manufacturer

**Zhejiang Hyxi Technology Co., Ltd.**  
Room 216, Block A, Building 1, No. 57 Jiang'er Road, Changhe Street, Binjiang District, Hangzhou, Zhejiang Province - China

Name and address of the factory

**General Power Technology (HangZhou) Co., Ltd Yuhang Branch**  
Building 2, No. 11, Xihu Road, Huanghu Town, Yuhang District, 311118 Hangzhou City, Zhejiang Province - China

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

102,4V, 50Ah, 5,12kWh

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

HYX-E50-H3

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CNDQ-ESH-P25040553

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 16/10/2025

Signature:

  
LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
33 avenue du Général Leclerc  
92260 FONTENAY-AUX-ROSES  
Certification Officer